



County of Riverside  
**DEPARTMENT OF ENVIRONMENTAL HEALTH**

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

**CITATION FOR NON COMPLIANCE – WATER SYSTEM NO. 3302063  
NO. 05\_63\_16C\_022**

Re: Wildomar OHV- USFS  
System No. 3302063

Date: September 23, 2016

To: Cleveland National Forest.  
Attn: Noelle Graham- Wakosk  
10845 Rancho Bernardo Rd. Ste. 200.  
San Diego CA, 92127

Section 116650, Article 9, Chapter 4, Part 12, Division 104 of the California Health and Safety Code (H&S Code), authorizes the issuance of a citation for failure to comply with the requirements of the California Safe Drinking Water Act, or any regulation, standard, permit order issued there under.

**VIOLATION**

The Department of Environmental Health (Department), hereby issues a citation to Wildomar OHV-USFS for the following violations:

1. Title 22 of the California Code of Regulations (CCR), Section 64426.1 (b) (4). Specifically, Wildomar OHV-USFS failed the Total Coliform Maximum Contaminant Level (MCL) during the month of July 2016. For a public water system which collects fewer than 40 samples per month, more than one sample collected during any month is total coliform-positive; or any repeat sample is fecal coliform-positive or E.coli-positive; or any repeat sample following a fecal coliform-positive or E.coli-positive routine sample is total coliform-positive.

**CHRONOLOGY OF EVENTS**

On July 22, 2016, Jeff Heghton collected two routine samples from the distribution system (Wildomar OHV and Wildomar camp ground). On <sup>July</sup> 24, 2016 Noelle was notified by the lab that both samples were total coliform present and E. coli absent. On July 25<sup>th</sup> Noelle Graham emailed this department with a notification of incident and informing the Department that resampling would not be conducted until the following Thursday. On July 28<sup>th</sup> Jeff Highton collected two resamples at the above sample sites. On July 30<sup>th</sup> Jeff was notified by the lab that

---

Office Locations • Blythe • Corona • Hemet • Indio • Murrieta • Palm Springs • Riverside

---

Phone (888)722-4234  
[www.rivcoeh.org](http://www.rivcoeh.org)

the samples were total coliform present and E. coli absent. On August 8<sup>th</sup> two cycle test were conducted by Arnold Perez. The lab reported samples to be absent for total coliform and E. coli on August 10, 2016. On August 11<sup>th</sup>, Mr. Perez provided this Department an update on what was done to correct the condition. The wells were disinfected and flushed, prior to cycle test. On August 16, 2016 cycle sampling was conducted at both sample sites. Samples were all absent for total coliform and E. coli.

## DIRECTIVES

All consumers served by this water system must be notified of this violation, as required in Section 64426.1 (c).

Your public water system must be maintained so that the total coliform MCL is not violated. Consult with this Department, or other qualified water professional, to correct and/or prevent reoccurrence of this violation.


The required coliform bacteria follow-up sampling to an unsatisfactory routine sample is described below. This must be completed each and every time that a routine coliform bacteria sampling is unsatisfactory.

1. Within 24 hours of being notified of an unsatisfactory coliform bacteria result by your laboratory, collect four resamples. If you are unable to collect the resamples within 24 hours, contact this Department. Collect the resamples at the sample tap where the unsatisfactory sample was taken, an upstream sample within 5 service connections of the unsatisfactory site, a downstream sample within 5 service connections of the unsatisfactory site, and a sample at the source(s) of water for the distribution system. All active wells must be sampled. If the direction of flow in the distribution system is not known, or if the distribution system is quite small, contact this Department for guidance. **It was determined that only four resamples can be collected at this system by conducting a cycle test. The system must be sampled after a 1 minute flush, after a 5 minutes flush, then after 15 minutes of flushing and a final sample after 30 minutes of flushing.**
2. If any of the resamples are unsatisfactory, additional sets of resamples must be taken. Contact this Department for guidance.
3. In the month following the unsatisfactory sample collect four coliform bacteria samples by following the cycle test mentioned above. Conducted on 8/16/2016

## FURTHER ENFORCEMENT ACTION

Failure to comply with this notice and/or failure to comply with Title 22 of the California Code of Regulations may result in assessment of administrative penalties. This Department does not waive any further enforcement action by issuance of this citation.

If you have any questions, please contact Daisy Ciudad Real at (951) 955-8980.

  
Daisy Ciudad Real, MPH, REHS

CERTIFIED MAIL 70150640000607672801